






Cooperative Fire Protection
since 1927

TEHAMA COUNTY FIRE DEPARTMENT

Protection and Planning Bureau

633 Washinton Street RM 22, Red Bluff, CA 96080 (530) 527-7986


Address Requirements




EACH NUMBER:
At Least 4-in. high,
½-in. wide

Reflective, on
contrasting
background

Numbers must be visible from both directions of travel.




Driveway Requirements



Driveways 150-ft. to 800-ft. shall have one turnout near Midpoint.

Driveways over 800-ft. shall have one turnout every 400-ft.

Driveways over 300-ft. must have a turnaround within 50-ft. of building.



NOTE:
Scale should be
1:50 or finer.
(i.e., 1:40)

Denote each
structure or
driveway as
"Existing" or
"Proposed."

Roadway

